



211221340013

检 测 报 告

TEST REPORT

报告编号: ZRJC-GW-202603104 (1)

项目名称: 安庆职业技术学院直饮水机水质检测

委托单位: 上海呱呱物联科技有限公司

受检单位: 安庆职业技术学院



安 徽 众 锐 质 量 检 测 有 限 公 司

Anhui Zhongrui Quality Test Co.,Ltd.



扫描全能王 创建

安徽众锐质量检测有限公司

检测报告

报告编号: ZRJC-GW-202603104 (1)

共 2 页 第 1 页

委托单位	上海呱呱物联科技有限公司	检测类别	委托
受检单位	安庆职业技术学院		
地址	安徽省安庆市元山东路 99 号安庆职业技术学院		
样品类别	直饮水	样品性状	液体
送样日期	2026-03-27	检测日期	2026-03-27~2026-03-29
执行标准	《饮用净水水质标准》 CJ 94-2005		
检测依据	GB/T 5750.4-2023、 GB/T 5750.7-2023、 GB/T 5750.12-2023		
检测项目	详见附页。		
主要检测仪器	RW7 多参数水质分析仪 (ZR0701)、BJPX-1-100 生化培养箱 (ZR1191)		
检测结论	所检项目符合《饮用净水水质标准》 CJ 94-2005 标准要求		
备注	检测结果仅对送检样品负责。		

安徽众锐质量检测有限公司



批准:

审核:

编制:



扫描全能王 创建

安徽众锐质量检测有限公司检测报告附页

报告编号: ZRJC-GW-202603104 (1)

共 2 页 第 2 页

检测结果

样品名称	检测项目	检测结果	标准限值
安庆职业技术学院 院学生公寓楼一 号楼一层西北面 (恒温直饮水)直 饮水机水样	色度 (铂钴色度单位)	<5	5
	浑浊度/NTU	<0.5	0.5
	臭和味	无异臭、异味	无异臭、异味
	肉眼可见物	无	无
	pH	6.87	6.0~8.5
	耗氧量 (COD _{Mn} 法, 以 O ₂ 计) (mg/L)	0.33	2.0
	菌落总数 (CFU/mL)	2	50
	总大肠菌群数 (MPN/100mL)	未检出	不得检出

(以下空白)

众锐检测



注 意 事 项

REMARK

1. 报告无“检验专用章”或检验单位公章无效。

The test report is invalid if there are not the marks of the special-purpose stamps for test or the testing laboratory's official stamps.

2. 未经本检测公司书面批准，不得复制检验报告。

The test report shall not be reproduced except in full, without written approval of the testing laboratory.

3. 报告无主检、审核、批准人签章无效。

The test report is invalid without the signatures of authorized personnel who tested, audited, and approved it.

4. 报告涂改无效。

The test report is invalid if altered.

5. 送样委托检验，仅对来样负责。

As to entrusted tests, the results presented in the test reports relate only to the received samples.

6. 在接到报告一个月之内，请来我检测公司办理退样手续，逾期按无主处理。

Please take back the samples within one month after receiving the test report. If the time limit is exceeded, the testing laboratory shall handle them. at will.

7. 未经书面许可，本报告不得用于任何广告宣传。

The test report shall not be used for advertisements or other publicity purposes, without written approval of the testing laboratory.

8. 本报告解释以中文为准。

In case of discrepancy, the original version in Chinese shall prevail.

检测地址：合肥市蜀山区白莲岩路与振兴路交叉口东南角联东U谷11号楼安徽省合肥市经济技术开发区丹霞路与天都路交叉口佛掌路标准厂房4号楼、肥西经开区大陶岗路与王岗路交叉口宜鑫汽车配件2#厂房

Test Address: 11 th Building of LIANDO U Valley,Southeast of the intersection of Bailianyan Road and Zhen xing Road , Shushan District of Hefei、 Fo Zhang Road standard factory building No.4,Hefei Economic and Technological Development Area,Anhui、 Yixin Auto Spare Parts No. 2 Factory at the intersection of Da Taogang Road and Wanggang Road, Feixi Economic Development Zone.

邮编：230601

Post Code: 230601

传真：0551-63817280

Fax: 86-0551-63817280

业务联系电话：0551-63817905 63817631 63817280 63817302 63817353

Telephone for Contact Business: 0551-63817905 63817631 63817280 63817302 63817353

报告咨询电话：0551-63817155

Telephone for Inquiry Reports: 86-0551-63817155

